

- 1. THE FULL LENGTH OF THE SERVICE DITCH SHALL BE COMPACTED IN 6" LAYERS WITH MECHANICAL TAMP, TO 95% STANDARD PROCTOR.
- 2. THE CITY SHALL MAKE TAPS ON EXISTING LINES
- 3. BENDS 1/16, 1/8, 1/4 AS REQUIRED.
- 4.FIRST BEND SHALL DCCUR BEHIND BACK OF CURB UNLESS SPECIFICALLY APPROVED BY THE UTILITIES ENGINEERING MANAGER.
- 5.ALL LATERALS 60' DR LONGER SHALL BE 6".
- 6,ND MATERIAL TRANSITIONS (LATERAL & STACK MUST BE ALL PVC OR ALL DIP)
- 7. WYES ONLY, NO TEES, SADDLES MAY ONLY BE USED ON EXISTING SEWER LINES.

CITY OF SALISBURY, N.C. STANDARD DETAIL	DATE: OCTOBER 17, 2006   AMENDED: MAY 19, 2009
SEWER SYSTEMS	NOT TO SCALE
TAP & STUB-DUT	STANDARD SS-5